

1 Q. With reference to IC-NLH-1, provide a detailed comparison of the estimated present
2 and future rate impacts for Hydro's customers (as determined by what rates would
3 be applied for by Hydro, and assuming the applied for rates were approved by the
4 Board) of having proceeded with the Holyrood gas turbine overhaul in 2011, as
5 compared to the the lease, installation, maintenance and use of the diesel units
6 which are the subject of the present Application.

7

8

9 A. Please refer to Hydro's response to IC-NLH-001. Since the 2011 Capital Budget
10 proposal to overhaul the gas turbine would not have resulted in a working
11 blackstart solution, its costs cannot be meaningfully compared to the costs that are
12 the subject of the present Application.