

1 Q. For how long a period has Holyrood operated without an effective blackstart  
2 solution at the Holyrood location?

3

4

5 A. Please refer to Hydro's response to IC-NLH-010 for the history of Holyrood  
6 blackstart capability following Hydro's determination in January 2012 that the  
7 Holyrood gas turbine would no longer be available for this functionality. Prior to  
8 January 2012, the Holyrood gas turbine was available for blackstart functionality.