

1 Q. Provide an update on the installation of black start capability at Holyrood, including  
2 a summary of work completed, providing details on installation, testing,  
3 outstanding work and associated costs incurred to date.

4

5

6 A. The eight diesel units have been successfully installed at the Holyrood facility, with  
7 over head power lines, shore power lines, and plant interconnections completed.

8 All units have been load tested and commissioned. Please refer to Hydro's

9 response to DD-NLH-002 for commissioning status and outstanding work. Capital

10 costs to date are: \$814,291.