

1 Q. Further to the response to NP-NLH-008 as the new combustion turbine project is  
2 proceeding with an expected in service date of December 7, 2014, state the value of  
3 the capitalized assets proposed in the Application that will continue to be utilized  
4 by Hydro.

5

6

7 A. The blackstart diesel units will remain in service until the new combustion turbine's  
8 infrastructure to blackstart the Holyrood plant is commissioned. The  
9 commissioning of this function of the combustion turbine will be carried out when  
10 the station service for a thermal unit at Holyrood can be taken out of service to  
11 perform a blackstart test. Winter operating conditions and system loading will  
12 impact the timing of when this can occur.

13

14 Once the blackstart diesels are removed from service following the commissioning  
15 of the blackstart function of the new combustion turbine, the overhead distribution  
16 lines and electrical infrastructure put in place for the blackstart diesels will continue  
17 to be used as they will connect the new combustion turbine into the 4,160 volt  
18 system of the Holyrood plant for the purpose of blackstarting the plant when the  
19 Holyrood TS infrastructure is not available. The capitalized cost of the assets that  
20 will remain is \$660,164.