T	Q.	In the 2012 Capital Expenditures and Carryover Report, page 5, Hydro has indicated
2		in its Carryovers to 2013 that \$3,743,600 remains to be expended in 2013 on the
3		Upgrade Gas Turbine Plan Life Extension - Hardwoods project. In the report
4		provided with the current application, Hardwoods Gas Turbine Alternator
5		Replacement 2013, page 14, Hydro states that \$2.1 million of the originally
6		approved project will no longer be necessary.
7		
8		Please provide details of the work that remains of the original project to be
9		undertaken in 2013, and explain how the remaining approved amount of the
10		original project, \$1,643,600, relates to the current request for approval of an
11		expenditure of \$8,015,800.
12		
13		
14	A.	The remaining approved amount of the original project, \$1,643,600 is associated
15		with the remaining scope items listed below and does not relate to the current
16		request for approval of an expenditure of \$8,015,800.
17		
18		The remaining scope items from the original project that will be completed in 2013
19		include the following:
20		 Replacement of electrical systems;
21		 Control and Instrumentation systems modifications;
22		 Recoating of structures and replacement of cladding; and
23		 Installation of overhauled engines and new pumps.