

1 Q. **Reference: Figure 9 – Alternative 2 Proposed Oxen Pond Terminal Station T1 and**
2 **T2 Replaced with 250 MVA Transformers – 230 kV Bus Tie Breaker Installed, page**
3 **47.**

4 Please confirm whether Alternative 2 is Hydro's preferred solution for the proposed
5 addition.

6

7

8 A. Hydro's preferred solution to increase the transformer capacity in the Hardwoods –
9 Oxen Pond Loop is Alternative 2 as outlined in Figure 9, page 47 and Figure 10, page
10 48.