

1 Q. At page 2 of the Executive Summary provided by System Improvements, Inc.
2 (Appendix A), it is stated that: "The control circuitry for the secondary pump calls
3 for a re-start based on both loss of the primary AC pump and loss of lube oil
4 pressure. The secondary pump re-started three minutes after the unit tripped."

5

6 (i) Has it been determined how long after failure of the primary AC pump that
7 lube oil pressure was lost?

8

9 (ii) Based on Hydro's understanding of how long after failure of the primary AC
10 pump that lube oil pressure was lost, was the re-start of the secondary AC
11 pump at three (3) minutes within the expected time frame?

12

13

14 A. (i) With the loss of the AC pumps and the failure of the DC pump to maintain
15 adequate lube oil capacity, lube oil pressure and flow was lost immediately
16 after the unit trip.

17

18 (ii) No, it is expected to start immediately. The second AC pump is powered
19 from the Holyrood switchyard. As such, its power supply is external to the
20 plant generation systems. Analysis has shown that this external power was
21 available to the plant for approximately eight minutes after the unit trip, but
22 at an extremely depressed level (due to the island wide power system issues
23 that existed during the extreme weather event of January 11, 2013). The
24 voltage level of the external power was sufficiently low to prevent the
25 second AC pump from starting in response to the loss of the primary AC
26 pump. The second pump was started via plant diesel generators three
27 minutes after the unit trip.