

1 Q. Black Tickle Diesel Plant: Please provide the actual load on the Black Tickle system
2 in 2013 and 2014 and the forecast of load in the future.

3

4

5 A. Please see the following table that provides the actual and forecast load
6 information for the Black Tickle system. The forecast is sourced to Hydro's load
7 forecast for the Labrador isolated systems completed in June of 2014.

8

Peak and Energy Requirements for Black Tickle		
	Net Peak (kW)	Net Energy (MWh)
2013 Actual	266	1,092
2014 Actual	315	1,136
2015 F	259	1,063
2016 F	254	1,044
2017 F	250	1,026
2018 F	245	1,007
2019 F	241	989