

1 Q. With respect to the 6-year maintenance that was 5 months overdue when the
2 Sunnyside B1L03 breaker malfunctioned, please provide any documentation, as of
3 the time that maintenance became overdue and up to the January 2014 incidents,
4 that indicated when Hydro did plan to conduct 6-year maintenance on the air blast
5 circuit breaker. If there was no such plan, describe what Hydro's plans at that time
6 were for maintenance prior to replacement in 2015.

7

8

9 A. Each year, the annual work plan is developed to highlight work to be completed
10 during the maintenance season. This is normally finalized during the first quarter of
11 the year, with outages and work scopes discussed. Sunnyside B1L03 breaker
12 maintenance was deferred in 2013 in order to carry out more critical maintenance
13 activities as determined by Short Term Planning and Scheduling, the Work
14 Execution and Long Term Asset Planning Groups. There were no indications of
15 concern with breaker B1L03 and it had successfully opened on August 9, 2013, and
16 closed on August 10, 2013.

17

18 The annual work plan for 2014 was not finalized at the time of the incident on
19 January 2014. However, when developing an annual work plan, backlog
20 maintenance on critical assets is reviewed and included in the plan. Sunnyside
21 B1L03 would have been added to the 2014 annual work plan as an overdue breaker
22 to be completed during the 2014 maintenance season.