

1 Q. For the Holyrood B1L17 overhaul, state whether Hydro used \$108,200 of consultant
2 labor because Hydro personnel were not qualified for the DLF overhaul work,
3 because Hydro lacked the resources because of other work at that time, or for
4 some other reason and explain the response.

5

6

7 A. Hydro used \$108,200 of consultant labor to complete the overhaul of Holyrood
8 breaker B1L17 (type DLF air blast circuit breaker), due to the fact that while Hydro's
9 staff are very experienced in completing overhauls on DCVF type air blast circuit
10 breakers, they have limited experience in overhauling more complex DLF type air
11 blast breakers (such as B1L17 at Holyrood). Please see Hydro's response to PR-
12 PUB-NLH-080.