## PR-PUB-NLH-103 NLH 2015 Prudence Review

## Page 1 of 1

1	Q.	Please provide the date when the 8x2 MW diesel black start capability was in
2		service and the date when it no longer was necessary due to completion of the new
3		CT.
4		
5		
6	A.	The eight x 2 MW diesel blackstart capability was placed in service on July 25, 2014.
7		This blackstart capability is currently in service and will remain in service until the
8		blackstart capability of the new CT has been proven. The commissioning of the new
9		CT equipment required to provide this capability is currently ongoing and is
10		expected to be completed in the summer of 2015.