

1 Q. Please identify all occasions on which black start was unavailable at any time after
2 the 8x2 MW diesel units first became available and prior to new CT availability and
3 explain the reasons for such unavailability.

4

5

6 A. There have been no occasions where blackstart was required. A blackstart of Unit 3
7 (and thereby the plant) requires seven of the diesel units. There have been no
8 occasions where the blackstart was unavailable since the first availability of the
9 eight x 2 MW diesel units. Please refer to Hydro's response to PR-PUB-NLH-104.