

1 Q. Explain why the Newfoundland Power mobile unit was considered for black start
2 capability and how it meets black start needs, given that its capacity (7.5 MW) was
3 well below any of the previously proposed solutions.
4

5

6

7 A. In addition to the Newfoundland Power (NP) mobile gas turbine, NP's 2.5 MW
8 mobile diesel unit was moved to the Holyrood Thermal Generating Station (HTGS).
9 The combined capability of these units had the potential for providing blackstart.

10 Please refer to Hydro's responses to CA-NLH-001 and PUB-NLH-029 from its

11 Application, *Installation of Diesel Units for the Purpose of Blackstarting* and Hydro's
12 response to PR-PUB-NLH-111 for the reason for moving these units to the HTGS and
their potential use for blackstart.