

1 Q. Please confirm that in preparation for the winter of 2014-15, “spare” FD Fan motors
2 were procured for the Holyrood Plant and that no plan existed to replace the FD fan
3 motors.

4

5

6 A. Spare 4160 V motors were procured for the Holyrood Thermal Generating Station
7 as detailed in Hydro's Application, *Newfoundland and Labrador Hydro Application*
8 *pursuant to Subsection 41 (3) of the Act for the approval of the Purchase of Critical*
9 *Spares for the Holyrood Thermal Generating Station.*

10

11 The decision to procure these FD fan motors was made following: (i) the experience
12 of a failure of one of the motors; and (ii) the completion in 2014 of Hydro's critical
13 spares review. Prior to these two events, the procurement of a spare FD fan motor
14 was not fully justified as noted in Hydro's response to PR-PUB-NLH-012.