

1 Q. Further to the response to PR-PUB-NLH-074, page 2, please confirm that the 2 to 8
2 year breaker maintenance frequency provided by Canadian utilities was for ABCBs
3 and not for all types of breakers.

4

5

6 A. It is confirmed.