


1 Q. In a meeting with Hydro management on May 29, 2015, Hydro stated that a  
2 technical analysis was completed that concluded that the Newfoundland Power  
3 mobile turbine accompanied by a Newfoundland Power mobile diesel generator  
4 was a viable option for black start at the Holyrood Plant. Please provide the analysis  
5 completed by Hydro at that time as well as any other information that led Hydro to  
6 this conclusion.

7

8

9 A. Please see PR-PUB-NLH-172 Attachment 1 for the analysis completed by Hydro. As  
10 noted in more detail in Hydro's response to PR-PUB-NLH-173, the primary purpose  
11 of having the Newfoundland Power mobile generation at Holyrood (as opposed to  
12 another location on the Avalon) was to provide additional station service power and  
13 to enable pre-warming of ancillary equipment. As well, the analysis indicated that  
14 the Newfoundland Power mobile units could potentially be utilized as a blackstart  
15 backup.

	<u>MARCH 6, 2013</u>
Approved for Release	Date

# ANALYSIS OF HOLYROOD UNIT 2 BOILER FEED PUMP EAST START-UP USING NEWFOUNDLAND POWER'S GAS TURBINE / MOBILE DIESEL

Newfoundland and Labrador Hydro

March 2013





## Table of Contents

	<u>Page</u>
1. INTRODUCTION .....	1
2. SCOPE AND OBJECTIVE .....	1
3. MODEL DETAILS .....	2
3.1. NP Mobile Gas Turbine .....	2
3.2. NP Mobile Diesel.....	2
3.3. Unit 2 Boiler Feed Pump East .....	3
4. MOTOR STARTING ANALYSIS .....	5
5. CONCLUSION.....	9

APPENDIX A – NP Data Sheets for Mobile Gas Turbine

APPENDIX B – NP Date Sheets for Mobile Diesel Generator

APPENDIX C – PSS®E Data Sheets for Gas Turbine and Mobile Diesel Generator

APPENDIX D – 3000 HP Induction Motor Data

APPENDIX E – PSS®E Data for 3000 HP Induction Motor Data

## **1. INTRODUCTION**

This report provides motoring starting analysis of Unit 2 Boiler Feed Pump East during a Plant Black Start condition utilizing Newfoundland Power's Mobile Gas Turbine and Diesel units only. This analysis was requested as a result of the January 11<sup>th</sup>, 2013 outage and subsequent installation of Newfoundland Power (NP) back-up generation at Holyrood Plant to supply emergency generation to the Avalon as well as potential Black Start capability of the Holyrood Plant.

## **2. SCOPE AND OBJECTIVE**

The objective of this analysis is to provide an assessment of the capability of both NP's portable generation sources being able to start the largest motor in the Holyrood Plant, which is the 3000Hp Boiler Feed Pump on Unit 1 or 2.

The scope of the study included the modeling and motor starting analysis of Unit 2 Boiler Feed Pump East utilizing NP's portable generation sources. Determination of operation of plant protective relays due to under voltage conditions is not in the scope of this work. The study involved the dynamic analysis of motoring starting using Version 33 of PSS<sup>®</sup>E software from Siemens PTI.

### **3. MODEL DETAILS**

A simplified load flow model of Holyrood 4.16 kV system has been developed for analysis as depicted in Figure 1. This model includes NP's 7.5 MVA gas turbine generator connected directly to Holyrood plant Station Service Bus SB12 and NP's 3.06 MVA diesel genset connected through two transformers to Station Service Bus SB12. The 4.16 kV cables between the Unit Boards and Station Service Boards have been modelled as well. Finally, a modest plant load of 1 MW has been assumed with both NP generators operating prior to starting of Unit 2 Boiler Feed Pump East.

The following model details have been assumed:

#### **3.1. NP Mobile Gas Turbine**

A 7.5 MVA mobile gas turbine with generator voltage of 4.16 kV is modelled and Appendix A outlines NP's data sheets for this unit. PSS<sup>®</sup>E dynamics model for this unit are attached in Appendix C, these include the following:

- **GENROU** (Round Rotor Generator Model), data as per NP's data sheets in Appendix A.
- **IEEET2** (IEEE Type 2 Excitation System), this model was copied from the existing Greenhill Gas Turbine data with exception VRmax = 3.0 instead of 2.5.
- **GAST** (Gas Turbine-Governor Model), this model was copied from the existing Greenhill Gas Turbine data with exception Vmax = 1.0 instead of 0.8.

#### **3.2. NP Mobile Diesel**

A 3.06 MVA mobile diesel with generator voltage of 4.16 kV is modelled and Appendix B outlines NP's data sheets for this unit. PSS<sup>®</sup>E dynamics model for this unit are attached in Appendix C, these include the following:

- **GENROU** (Round Rotor Generator Model), data as per NP's data sheets in Appendix B.
- **IEEET2** (Same as Gas Turbine model).
- **GAST** (Same as Gas Turbine model).

### **3.3. Unit 2 Boiler Feed Pump East**

This motor is a Westinghouse, 3000 Hp, induction motor with full load current rating of 350A. Appendix D outlines the technical data associated with this motor, including a locked rotor current of 581% of rated full load. PSS®E's Induction Motor Dynamics (IMD) program estimates the motor equivalent circuit data based on full load and locked rotor current, starting and pull up torque. Results of these parameters are then used in PSS®E's Induction Motor Load Model CIM5BL to dynamically simulate a motor starting analysis. The results of the IMD program for motor equivalent and PSS®E model description are outlined in Appendix E.

SIMPLIFIED HOLYROOD PLANT MODEL  
 BLACK START WITH 2 NP GENERATORS  
 TUE, MAR 05 2013 13:08





Figure 1  
 Simplified Model of Holyrood 4.16kV Network



#### 4. MOTOR STARTING ANALYSIS


The simplified Holyrood system model of a black start condition forms the basis of the motor starting analysis. It is assumed an initial plant load of 1 MW is being fed by both NP's gas turbine and diesel genset in isolation from NLH system. Voltages prior to motor starting are unity.

Results of the dynamic motor starting simulation are outlined in Figures 2 through 6 below.




**Figure 2**  
**Motor Starting – 4.16kV Bus Voltage**

As can be seen from Figure 2, motor starting will cause a very substantive drop in voltage on the 4.16kV bus to approximately 0.71 pu for roughly 0.5 seconds before it begins to recover. The voltage is below 0.9 pu for approximately 2 seconds.




**Figure 3 - Motor Starting Current**




**Figure 4 - Motor Starting Speed vs. Time**

Figure 3 outlines the expected motor starting current in pu of the full load current of 350A. It is expected the starting current of the motor to exceed 5 pu, which significantly depresses the 4.16 kV bus voltage. Figure 4 outlines the pu speed of the motor from stand still to rated speed of 3580 RPM, it will take approximately 4 seconds to bring the motor from stand-still to rated speed. Documentation from the manufacturer states that normal starting at 100% voltage should only take 2.0 seconds, while at 90% voltage, motor starting should be about 2.9 seconds. With the NP generators, the expected voltage will be close to 70% which will reduce the starting torque, thus increase the time to rated speed.

Figure 5 outlines the expected MW power output from both NP generators. Both units in parallel are capable of producing the required output for motor start. Figure 6 outlines the expected MVAR output of both generators during motor start-up. It appears that the gas turbine exceeds its rated output for roughly 3 seconds. The capability of the unit to operate for this duration is questionable and needs verification from the manufacturer.



**Figure 5 - NP Generator Power**



**Figure 6**  
**NP Generator Reactive Power Output**

## **5. CONCLUSION**


Based on this preliminary analysis it appears with both NP generators operational that starting of a 3000 Hp Boiler Feed Pump is theoretically possible, but increased starting time and depressed voltages can be expected on the 4.16 kV buses within the plant to a value close to 70% of nominal. Several areas of concern have been identified and need to be addressed if Black Start capability will be required from these units. They are as follows:

1. Are there any under voltage relay protection settings on the 4.16 kV or 600 V system within the plant that could cause equipment tripping as a result of the depressed voltages during motor starting.
2. Does the NP Mobile Gas Turbine generator / excitation system have the capability to supply up to 150% of nameplate rating for several seconds without tripping off-line.

**APPENDIX A**  
**NP DATA SHEETS**  
**FOR MOBILE GAS TURBINE**





**Holyrood Black Start – Motor Start Simulation**



<p>G. Richard Spurrell</p> <p>SIGNATURE</p> <p>2008-01-21</p> <p>DATE</p>	<p>SINGLE LINE DIAGRAM</p>		
	<p>MOBILE GAS TURBINE</p>		
<p>PROVINCE OF NEWFOUNDLAND PERMIT HOLDER</p> <p>The Permit Allows</p> <p>NEWFOUNDLAND POWER INC.</p> <p>To provide Professional Engineering in Newfoundland and Labrador</p> <p>Permit No. as Issued by APES 10048</p> <p>which is valid for the year 2008.</p>	Date: 2008-01-21	Page 1 Of 1	
	App:	SLD No. 1-615	



### MGT Screen Shots



**APPENDIX B**



**NP DATA SHEETS**

**FOR MOBILE DIESEL GENERATOR**





### MD3 Screen Shots



**GENERATOR DATA**

**MARCH 28, 2012**

For Help Desk Phone Numbers [Click here](#)

**Selected Model**

Engine: 3516 Generator Frame: 825 Genset Rating (kW): 1825.0 Line Voltage: 600  
 Fuel: Diesel Generator Arrangement: 3062928 Genset Rating (kVA): 2281.0 Phase Voltage: 346  
 Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 2194.9  
 Duty: PRIME Connection: SERIES STAR Application: EPG Status: Pending

Version: 40400/39715/40365/31

**Spec Information**

Generator Specification			Generator Efficiency		
Frame: 825	Type: SR4B	No. of Bearings: 1	Per Unit Load	kW	Efficiency %
Winding Type: FORM WOUND	Flywheel: 21.0		0.25	456.3	93.5
Connection: SERIES STAR	Housing: 00		0.5	912.5	96.1
Phases: 3	No. of Leads: 6		0.75	1368.8	96.9
Poles: 4	Wires per Lead: 8		1.0	1825.0	97.2
Sync Speed: 1800	Generator Pitch: 0.6667		1.1	2007.5	97.2

Reactances	Per Unit	Ohms
SUBTRANSIENT - DIRECT AXIS $X'_d$	0.1584	0.0250
SUBTRANSIENT - QUADRATURE AXIS $X'_q$	0.1470	0.0232
TRANSIENT - SATURATED $X'_d$	0.2357	0.0372
SYNCHRONOUS - DIRECT AXIS $X_d$	2.9815	0.4705
SYNCHRONOUS - QUADRATURE AXIS $X_q$	1.4220	0.2244
NEGATIVE SEQUENCE $X_2$	0.1527	0.0241
ZERO SEQUENCE $X_0$	0.0095	0.0015

Time Constants	Seconds
OPEN CIRCUIT TRANSIENT - DIRECT AXIS $T'_{d0}$	6.2860
SHORT CIRCUIT TRANSIENT - DIRECT AXIS $T'_d$	0.4964
OPEN CIRCUIT SUBTRANSIENT - DIRECT AXIS $T''_{d0}$	0.0087
SHORT CIRCUIT SUBTRANSIENT - DIRECT AXIS $T''_d$	0.0077
OPEN CIRCUIT SUBTRANSIENT - QUADRATURE AXIS $T''_{q0}$	0.0068
SHORT CIRCUIT SUBTRANSIENT - QUADRATURE AXIS $T''_q$	0.0061
EXCITER TIME CONSTANT $T_e$	0.2225
ARMATURE SHORT CIRCUIT $T'_a$	0.0637

Short Circuit Ratio: 0.44 Stator Resistance = 0.0021 Ohms Field Resistance = 1.003 Ohms

Voltage Regulation		Generator Excitation		
Voltage level adjustment: +/-	5.0%	No Load	Full Load, (rated) pf	
Voltage regulation, steady state: +/-	0.5%		Series	Parallel
Voltage regulation with 3% speed change: +/-	0.5%	Excitation voltage:	8.28 Volts	35.89 Volts
Waveform deviation line - line, no load: less than	3.0%	Excitation current	2.18 Amps	7.77 Amps
Telephone influence factor: less than	50			

**Holyrood Black Start – Motor Start Simulation**

**Selected Model**

Engine: 3516 Generator Frame: 825 Genset Rating (kW): 1825.0 Line Voltage: 600  
 Fuel: Diesel Generator Arrangement: 3062928 Genset Rating (kVA): 2281.0 Phase Voltage: 346  
 Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 2194.9  
 Duty: PRIME Connection: SERIES STAR Application: EPG Status: Pending

Version: 40400 /39715 /40365 /31

**Generator Mechanical Information**

**Center of Gravity**

Dimension X	0.0 mm	0.0 IN.
Dimension Y	0.0 mm	0.0 IN.
Dimension Z	0.0 mm	0.0 IN.

- "X" is measured from driven end of generator and parallel to rotor. Towards engine fan is positive. See General Information for details
- "Y" is measured vertically from rotor center line. Up is positive.
- "Z" is measured to left and right of rotor center line. To the right is positive.

Generator WT = 0 kg	* Rotor WT = 0 kg	* Stator WT = 0 kg
0.0 LB	0.0 LB	0.0 LB

Rotor Balance = 0.0508 mm deflection PTP  
 Overspeed Capacity = 100% of synchronous speed

**Generator Torsional Data**

TOTAL J = J1 + J2 + J3

K1 = Shaft Stiffness between J1 + J2 (Diameter 1)			K2 = Shaft Stiffness between J2 + J3 (Diameter 2)			
J1	K1	Min Shaft Dia 1	J2	K2	Min Shaft Dia 2	J3
0.0 LB IN. s <sup>2</sup>	0.0 MLB IN./rad	0.0 IN.	0.0 LB IN. s <sup>2</sup>	0.0 MLB IN./rad	0.0 IN.	0.0 LB IN. s <sup>2</sup>
0.0 N m s <sup>2</sup>	0.0 MN m/rad	0.0 mm	0.0 N m s <sup>2</sup>	0.0 MN m/rad	0.0 mm	0.0 N m s <sup>2</sup>
<b>Total J</b>						
0.0 LB IN. s <sup>2</sup>			0.0 N m s <sup>2</sup>			

**Selected Model**

Engine: 3516 Generator Frame: 825 Genset Rating (kW): 1825.0 Line Voltage: 600  
 Fuel: Diesel Generator Arrangement: 3062928 Genset Rating (kVA): 2281.0 Phase Voltage: 346  
 Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 2194.9  
 Duty: PRIME Connection: SERIES STAR Application: EPG Status: Pending

Version: 40400/39715/40365/31

Generator Cooling Requirements - Temperature - Insulation Data	
<b>Cooling Requirements:</b>	<b>Temperature Data: (Ambient 40 °C)</b>
Heat Dissipated: 52.6 kW	Stator Rise: 105.0 °C
Air Flow: 0.0 m <sup>3</sup> /min	Rotor Rise: 105.0 °C
Insulation Class: H	
Insulation Reg. as shipped: 100.0 MΩ minimum at 40 °C	
Thermal Limits of Generator	
Frequency:	60 Hz
Line to Line Voltage:	600 Volts
B BR 80/40	1893.0 kVA
F BR -105/40	2281.0 kVA
H BR - 125/40	2500.0 kVA
F PR - 130/40	2500.0 kVA



*Holyrood Black Start – Motor Start Simulation*

**Selected Model**


Engine: 3516 Generator Frame: 825 Genset Rating (kW): 1825.0 Line Voltage: 600  
 Fuel: Diesel Generator Arrangement: 3062928 Genset Rating (kVA): 2281.0 Phase Voltage: 346  
 Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 2194.9  
 Duty: PRIME Connection: SERIES STAR Application: EPG Status: Pending

Version: 40400 /39715 /40365 /31

**Starting Capability & Current Decrement**


**Motor Starting Capability (0.4 pf)**

SKVA	Percent Volt Dip
259	2.5
531	5.0
818	7.5
1,122	10.0
1,442	12.5
1,781	15.0
2,141	17.5
2,524	20.0
2,931	22.5
3,365	25.0
3,829	27.5
4,326	30.0
4,860	32.5
5,435	35.0
6,056	37.5
6,729	40.0



**Current Decrement Data**

E Time Cycle	AMP
0.0	13,755
1.0	9,566
2.0	8,836
3.0	8,523
4.0	8,265
5.0	8,020
7.5	7,446
10.0	6,917
12.5	6,431
15.0	5,985
20.0	5,197
25.0	4,530
30.0	3,974
35.0	3,995
40.0	4,207
45.0	4,464



Instantaneous 3 Phase Fault Current: 13755 Amps    Instantaneous Line - Line Fault Current: 12136 Amps  
 Instantaneous Line - Neutral Fault Current: 20404 Amps

**Selected Model**


Engine: 3516 Generator Frame: 825 Genset Rating (kW): 1825.0 Line Voltage: 600  
 Fuel: Diesel Generator Arrangement: 3062928 Genset Rating (kVA): 2281.0 Phase Voltage: 346  
 Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 2194.9  
 Duty: PRIME Connection: SERIES STAR Application: EPG Status: Pending

Version: 40400 /39715 /40365 /31

**Generator Output Characteristic Curves**


**Open Circuit Curve**

Field Current	Line - Line Volt
0.0	0
10.6	360
12.6	420
14.9	480
17.9	540
22.6	600
31.2	660
48.8	720
87.1	780
173.3	840



**Short Circuit Curve**

Field Current	Armature Current
0.0	0
29.8	1,317
34.8	1,537
39.7	1,756
44.7	1,976
49.7	2,195
54.6	2,415
59.6	2,634
64.6	2,854
69.5	3,073



**Selected Model**


Engine: 3516 Generator Frame: 825 Genset Rating (kW): 1825.0 Line Voltage: 600  
 Fuel: Diesel Generator Arrangement: 3062928 Genset Rating (kVA): 2281.0 Phase Voltage: 346  
 Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 2194.9  
 Duty: PRIME Connection: SERIES STAR Application: EPG Status: Pending

Version: 40409 /39715 /40365 /31

**Generator Output Characteristic Curves**


**Zero Power Factor Curve**

Field Current	Line - Line Volt
49.7	0
63.2	300
65.9	360
70.0	420
76.9	480
90.7	540
120.2	600
186.3	660
336.9	720
683.0	780



**Air Gap Curve**

Field Current	Line - Line Volt
0.0	0
10.4	360
12.2	420
13.9	480
15.7	540
17.4	600
19.2	660
20.9	720
22.6	780
24.4	840



---

**Selected Model**

Engine: 3516	Generator Frame: 825	Genset Rating (kW): 1825.0	Line Voltage: 600
Fuel: Diesel	Generator Arrangement: 3062928	Genset Rating (kVA): 2281.0	Phase Voltage: 346
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 2194.9
Duty: PRIME	Connection: SERIES STAR	Application: EPG	Status: Pending

Version: 40400 /39715 /40365 /31

**Reactive Capability Curve**

[Click to view Chart](#)

---

**Selected Model**

**Engine:** 3516   **Generator Frame:** 825   **Genset Rating (kW):** 1825.0   **Line Voltage:** 600  
**Fuel:** Diesel   **Generator Arrangement:** 3062928   **Genset Rating (kVA):** 2281.0   **Phase Voltage:** 346  
**Frequency:** 60   **Excitation Type:** Permanent Magnet   **Pwr. Factor:** 0.8   **Rated Current:** 2194.9  
**Duty:** PRIME   **Connection:** SERIES STAR   **Application:** EPG   **Status:** Pending

Version: 40480 (39715 /40365 /31

---

**General Information**

DM7828   Caterpillar Custom Generators (50 Hz, 60 Hz)  
Data for Custom SR4, SR4B, SR4B-HV, SR5 and SR5-HV  
Caterpillar generators built by Leroy Somer – USA and  
Leroy Somer – France.

Refer to DM7821 for explanation of all generator data in Technical  
Marketing Information (TMI) except generator efficiency for which the  
explanation is given below.

**GENERATOR EFFICIENCY**

Generator efficiency is the percentage of engine flywheel (or other  
prime mover) power that is converted into electrical output. The  
generator efficiency shown is calculated by the summation of all  
losses method, and is determined in accordance with the IEC Standard  
60034. The efficiency considers only the generator. There is no  
consideration of engine or parasitic losses here.

---

**Selected Model**

Engine: 3516 Generator Frame: 825 Genset Rating (kW): 1825.0 Line Voltage: 600  
Fuel: Diesel Generator Arrangement: 3062928 Genset Rating (kVA): 2281.0 Phase Voltage: 346  
Frequency: 60 Excitation Type: Permanent Magnet Pwr. Factor: 0.8 Rated Current: 2194.9  
Duty: PRIME Connection: SERIES STAR Application: EPG Status: Pending

Version: 40400 /39715 /40365 /31


**Internal Information**

Max Block Load : 0.0 Max Motor Load : 0.0 Max Single Step : 0.0  
Block Kg : 0.076 Motor Kg : 0.099 KVA Derate : 2281.0  
Derate Code : BR Temperature Rise: 105.0 Target kW: 1825.0

**The user information for this generator is unavailable for reference.  
Generator Data Uploaded On: October 06, 2011**

---

Caterpillar Confidential: Green  
Content Owner: Shane Gilles  
Web Master(s): [PSG Web Based Systems Support](#)  
Current Date: Wednesday, March 28, 2012 8:17:29 AM  
© Caterpillar Inc. 2012 All Rights Reserved.  
[Data Privacy Statement](#)



**APPENDIX C**

**PSS®E DATA SHEETS**

**FOR GAS TURBINE AND MOBILE DIESEL GENERATOR**





Holyrood Black Start – Motor Start Simulation



Generator Model Data Sheets  
 GENROU

PSS®E 33.3  
 PSS®E Model Library

1.19 GENROU

MOBILE GAS TURBINE (data provided by  
 MGT NP - Brad Tucker Jan.17/13)

Round Rotor Generator Model (Quadratic Saturation)

This model is located at system bus # \_\_\_\_\_ IBUS,


Machine identifier # \_\_\_\_\_ ID,

This model uses CONs starting with # \_\_\_\_\_ J,

and STATEs starting with # \_\_\_\_\_ K.

The machine MVA is \_\_\_\_\_ for each of \_\_\_\_\_ units = \_\_\_\_\_ MBASE.

ZSORCE for this machine is \_\_\_\_\_ + j \_\_\_\_\_ on the above MBASE



CONs	#	Value	Description
J		5.0	$T'_{do}$ (>0) (sec)
J+1		0.04	$T''_{do}$ (>0) (sec)
J+2		1.5	$T'_{qo}$ (>0) (sec)
J+3		0.08	$T''_{qo}$ (>0) (sec)
J+4		1.00	H, Inertia
J+5		0	D, Speed damping
J+6		0.2475	$X_d$
J+7		0.9	$X_q$
J+8		0.2779	$X'_d$
J+9		0.6	$X'_q$
J+10		0.1853	$X''_d = X''_q$
J+11		0.1	$X_l$
J+12		0.12	S(1.0)
J+13		0.60	S(1.2)

Note:  $X_d$ ,  $X_q$ ,  $X'_d$ ,  $X'_q$ ,  $X''_d$ ,  $X''_q$ ,  $X_l$ , H, and D are in pu, machine MVA base.

$X''_q$  must be equal to  $X''_d$ .

MVA base = 7.5

Holyrood Black Start – Motor Start Simulation



Generator Model Data Sheets  
 GENROU

PSS®E 33.3  
 PSS®E Model Library

MOBILE DIESEL MD3 (data provided by NP-Brad Tucker, Jan. 17/13)

1.19 GENROU

Round Rotor Generator Model (Quadratic Saturation)

This model is located at system # \_\_\_\_\_ IBUS, bus


Machine identifier # \_\_\_\_\_ ID,

This model uses CONs starting with # \_\_\_\_\_ J,

and STATEs starting with # \_\_\_\_\_ K.

The machine MVA is \_\_\_\_\_ for each of \_\_\_\_\_ units = \_\_\_\_\_ MBASE.

ZSORCE for this machine is \_\_\_\_\_ + j \_\_\_\_\_ on the above MBASE



CONs	#	Value	Description
J		5.0	T'do (>0) (sec)
J+1		0.04	T''do (>0) (sec)
J+2		1.50	T'qo (>0) (sec)
J+3		0.08	T''qo (>0) (sec)
J+4		1.0	H, Inertia
J+5		0	D, Speed damping
J+6		2.06	Xd
J+7		0.90	Xq
J+8		0.1663	X'd
J+9		0.6	X'q
J+10		0.1297	X''d = X''q
J+11		0.1	Xl
J+12		0.12	S(1.0)
J+13		0.60	S(1.2)

Note: Xd, Xq, X'd, X'q, X''d, X''q, Xl, H, and D are in pu, machine MVA base.

X''q must be equal to X''d.

MVAbase = 3.06

**SIEMENS**


Excitation System Model Data Sheets  
 IEEEET2

PSS®E 33.3  
 PSS®E Model Library

**6.40 IEEEET2**

ASSUMED SETTINGS SAME AS GREENHILL GAS TURBINE (except  $V_{RMAX} = 3$  instead of 0)  
 IEEE Type 2 Excitation System

This model is located at system bus # \_\_\_\_\_ IBUS,  
 Machine identifier # \_\_\_\_\_ ID,  
 This model uses CONs starting with # \_\_\_\_\_ J,  
 and STATES starting with # \_\_\_\_\_ K,  
 and VAR # \_\_\_\_\_ L.



CONs	#	Value	Description
J		0.035	$T_R$ (sec)
J+1		400	$K_A$
J+2		0.22	$T_A$ (sec)
J+3		3.0	$V_{RMAX}$ or zero
J+4		0	$V_{RMIN}$
J+5		0	$K_E$
J+6		1.0	$T_E (>0)$ (sec)
J+7		0.088	$K_F$
J+8		0.38	$T_{F1} (>0)$ (sec)
J+9		1.00	$T_{F2} (>0)$ (sec)
J+10		1.82	$E_1$
J+11		0.5	$S_E(E_1)$
J+12		2.43	$E_2$
J+13		0.86	$S_E(E_2)$

STATES	#	Description
K		Sensed $V_T$
K+1		Regulator output, $V_R$
K+2		Exciter output, EFD
K+3		First feedback integrator
K+4		Second feedback integrator

VAR	#	Description
L		$K_E$

All material contained in this documentation is proprietary to Siemens Industry, Inc., Siemens Power Technologies International.

**SIEMENS**

PSS<sup>®</sup>E 33.3  
 PSS<sup>®</sup>E Model Library


Turbine-Governor Model Data Sheets  
 GAST

**7.5 GAST**

ASSUMED MODEL FOR MOBILE DIESEL  
 AND GAS TURBINE, SAME AS GREENHILL GAS  
 TURBINE (except V<sub>max</sub>  
 increased from 0.8058 to  
 1.0)

Gas Turbine-Governor

This model is located at system bus # \_\_\_\_\_ IBUS,  
 Machine identifier # \_\_\_\_\_ ID,  
 This model uses CONs starting with # \_\_\_\_\_ J,  
 and STATEs starting with # \_\_\_\_\_ K,  
 and VAR # \_\_\_\_\_ L.



CONs	#	Value	Description
J		0.07	R (speed droop)
J+1		0.40	T <sub>1</sub> (>0) (sec)
J+2		0.10	T <sub>2</sub> (>0) (sec)
J+3		3.00	T <sub>3</sub> (>0) (sec)
J+4		1.0	Ambient temperature load limit, AT
J+5		2.0	K <sub>T</sub>
J+6		1.0	V <sub>MAX</sub>
J+7		0	V <sub>MIN</sub>
J+8		0	D <sub>turb</sub>

STATEs	#	Description
K		Fuel valve
K+1		Fuel flow
K+2		Exhaust temperature

VAR	#	Description
L		Load reference

V<sub>max</sub>, V<sub>min</sub>, D<sub>turb</sub> and R are in pu on generator MVA base.

IBUS, 'GAST', ID, CON(J) to CON(J+8) /

## **APPENDIX D**

### **3000 HP INDUCTION MOTOR DATA**








GraphiC 7.1 Feb. 19, 2013 1:59:28 PM

Version 1.0.8

### Induction Motor Starting Characteristics Calculated at 100% Line Voltage

Design.ID	8052AA	Customer	NEW FOUNDLAND & LABRADOR				
Engineer	T.NGUYEN	Application	ELECTRIC UTILITY PUMP				
Poles	2	Volts	4160	Rpm(fl)	3580	Load Curve	ASSUMED
Hp	3000	F1 Amps	350	Rpm(syn)	3600	Lock Amps(%)	581
Pf	0.92	Frame	5011	Load Wk <sup>2</sup>	70	F1 Torque(lb-ft)	4400
Phase	3	Hertz	60.0	Motor Wk <sup>2</sup>	423	Lock Torque(%)	78



TECO-Westinghouse Motor Company  
 Signature \_\_\_\_\_

Round Rock, Texas  
 Curve No.


Holyrood Black Start – Motor Start Simulation

GraphiC 7.1 Feb. 19, 2013 1:59:28 PM

Version 1.0.8

### Induction Motor Starting Characteristics Calculated at 90% Line Voltage


Design.ID	8052AA	Customer	NEW FOUNDLAND & LABRADOR				
Engineer	T.NGUYEN	Application	ELECTRIC UTILITY PUMP				
Poles	2	Volts	4160	Rpm(fl)	3580	Load Curve	ASSUMED
Hp	3000	F1 Amps	350	Rpm(syn)	3600	Lock Amps(%)	511
Pf	0.92	Frame	5011	Load Wk <sup>2</sup>	70	F1 Torque(lb-ft)	4400
Phase	3	Hertz	60.0	Motor Wk <sup>2</sup>	423	Lock Torque(%)	60




TECO-Westinghouse Motor Company  
 Signature \_\_\_\_\_

Round Rock, Texas  
 Curve No.

Holyrood Black Start – Motor Start Simulation



Holyrood Black Start – Motor Start Simulation





## **APPENDIX E**

### **PSS®E DATA FOR 3000 HP INDUCTION MOTOR DATA**





PSS<sup>®</sup>E 33.3  
 PSS<sup>®</sup>E Model Library

Load Characteristic Model Data Sheets  
 CIM5BL, CIM5OW, CIM5ZN, CIM5AR, CIM5AL

## 9.2 CIM5BL, CIM5OW, CIM5ZN, CIM5AR, CIM5AL

### Induction Motor Load Model

This model uses CONs starting with # \_\_\_\_\_ J,  
 and STATEs starting with # \_\_\_\_\_ K,  
 and VARs starting with # \_\_\_\_\_ L,  
 and ICON # \_\_\_\_\_ M,  
 and Reserved ICONs starting with # \_\_\_\_\_ N.

CONs	Value	Description
J	0.022	$R_A$
J+1	0.113	$X_A$
J+2	3.92	$X_m > 0$
J+3	0.047	$R_1 > 0$
J+4	0.034	$X_1 > 0$
J+5	0.00585	$R_2$ (0 for single cage) <sup>1</sup>
J+6	0.0430	$X_2$ (0 for single cage)
J+7	1.0	$E_1 \geq 0$
J+8	0.17	$S(E_1)$
J+9	1.2	$E_2$
J+10	0.52	$S(E_2)$
J+11	2.515	$M_{BASE}^2$
J+12	1	$PMULT$
J+13	0.58	$H$ (inertia, per unit motor base)
J+14	0	$V_1$ (pu) <sup>3</sup>
J+15	0.1667	$T_1$ (cycles) <sup>4</sup>
J+16	0.0833	$T_B$ (cycles)
J+17	1.0	$D$ (load damping factor)
J+18	0.756	$T_{nom}$ , Load torque at 1 pu speed (used for motor starting only) ( $\geq 0$ )

- 1 To model single cage motor: set  $R_2 = X_2 = 0$ .
- 2 When  $M_{BASE} = 0$ , motor MVA base =  $PMULT \times MW$  load. When  $M_{BASE} > 0$ , motor MVA base =  $M_{BASE}$ .
- 3  $V_1$  is the per unit voltage level below which the relay to trip the motor will begin timing. To disable relay, set  $V_1 = 0$ .
- 4  $T_1$  is the time in cycles for which the voltage must remain below the threshold for the relay to trip.  $T_B$  is the breaker delay time cycles.



*Holyrood Black Start – Motor Start Simulation*



Load Characteristic Model Data Sheets  
 CIM5BL, CIM5OW, CIM5ZN, CIM5AR, CIM5AL

PSS<sup>®</sup>E 33.3  
 PSS<sup>®</sup>E Model Library

STATES	Value	Description
K		$E'_q$
K+1		$E'_d$
K+2		$E''_q$
K+3		$E''_d$
K+4		$\Delta$ speed (pu)
K+5		Angle deviation

VARs	Value	Description
L		Admittance of initial condition Mvar difference
L+1		Motor Q
L+2		$T_{elec}$ (pu motor base)
L+3		$\Delta\omega$
L+4		T (pu on motor base) <sup>1, 2</sup>
L+5		$I_Q$
L+6		$I_D$
L+7		Motor current (pu motor base)
L+8		Relay trip time
L+9		Breaker trip time
L+10		MVA rating

<sup>1</sup> Load torque,  $T_L = T (1 + D\omega)^D$

<sup>2</sup> For motor starting,  $T=T_{nom}$  is specified by the user in CON (J+18).  
 For motor online studies,  $T=T_o$  is calculated in the code during initialization and stored in VAR (L+4).

ICON	Value	Description
M	2	IT, motor type (1 or 2)

Reserved ICONs	Value	Description
N		Relay action code
N+1		Relay trip flag
N+2		Breaker action code
N+3		Breaker trip flag

I, 'CIM5xx', LID, ICON(M), CON(J) to CON(J+18) /

**Holyrood Black Start – Motor Start Simulation**




PSS®E 33.3  
 PSS®E Model Library

Load Characteristic Model Data Sheets  
 CIM5BL, CIM5OW, CIM5ZN, CIM5AR, CIM5AL

LID is an explicit load identifier or may be \* for application to loads of any ID associated with the subsystem type.

Model suffix xx	I Description
BL	Bus number
OW	Owner number
ZN	Zone number
AR	Area number
AL	0



RATING : 3000 Hp @ assumed pf = 0.89  

$$\frac{3000 \times 746}{0.89} = 2.515 \text{ MVA}$$

H: MOTOR  $WK^2 = 423$   
 LOAD  $WK^2 = \frac{70}{493}$  (Assumed)

$$H = \frac{0.231 \times 10^{-6} (\text{RPM})^2 \times WK^2}{\text{KVA mach}}$$

$$H = \frac{0.231 \times 10^{-6} (3580)^2 \times 493}{2515}$$

H = 0.58

