

Q. Re: 2012 Capital Expenditure Status Report, Appendix A, Page 2 of 6

Please provide the locations of the substation switches which require replacement after the December 2011 thermo scanning.

A. Table 1 provides the location of the substation switches that need to be replaced as identified by the thermo scanning carried out in December 2011.

Table 1
Substation Switch Replacements

Substation	Designation	Type¹	Qty Req'd	Voltage (kV)
Broad Cove	BCV-03-DB	HSO	1	15
Broad Cove	BCV-03-DL	HSO	1	15
Big Pond	BIG-02-DL	HSO	1	15
Bonavista	BVA-01-DB	HSO	1	25
Bayview	BVS-T2-D	HSO	1	15
Bayview	BVS-03-DL	S/B	1	15
Carbonear	CAR-01-DB	HSO	1	15
Carbonear	CAR-T1-D	S/B	1	15
Cobb's Pond	COB-02-DL	HSO	1	25
Fermeuse	FER-01-DL	HSO	1	15
Gander	GAN-144L-DL	S/B-G/S	1	138
Grand Bay	GBS-01-DB	HSO	1	25
Grand Bay	GBS-01-DL	S/B	1	25
Glendale	GDL-01-DB	HSO	1	25
Glendale	GDL-02-DB	HSO	1	25
Glendale	GDL-04-DB	HSO	1	25
Glendale	GDL-73L-DL	S/B-G/S	1	66
Gillams	GIL-01-DB	HSO	1	25
Gillams	GIL-01-DL	HSO	1	25
Humber	HUM-356L-DB	S/B	1	66
Hardwoods	HWD-07-DB	HSO	2	25
Hardwoods	HWD-08-DB	HSO	1	25
Upper Island Cove	ILC-01-DB	HSO	1	15

¹ The abbreviations for "Type" represent the following:

S/B Sidebreak Switch
A/B Airbreak Switch
G/S Ground Switch
HSO Hookstick Operated Switch

Table 1
Substation Switch Replacements
(continued)

Substation	Designation	Type²¹	Qty Req'd	Voltage (kV)
Kelligrews	KEL-02-DL	HSO	3	25
Kelligrews	KEL-T1-D	HSO	3	25
Kenmount	KEN-69L-DL	S/B-G/S	1	66
Kenmount	KEN-54L-DL	S/B-G/S	1	66
Kenmount	KEN-35L-DB	S/B	1	66
Monkstown	MKS-02-DL	HSO	1	25
Molloy's Lane	MOL-19L-DL	S/B-G/S	1	66
Molloy's Lane	MOL-09-DB	HSO	1	15
Molloy's Lane	MOL-04-DB	HSO	1	15
Molloy's Lane	MOL-T1-DB	S/B	1	15
Memorial	MUN-14L-DB	S/B	1	66
New Chelsea	NCH-T1-FD	HSO	1	66
New Grand Falls	GFS-T2-DL	S/B	1	25
Northwest Brook	NWB-VR-ABP	HSO	3	25
Oxen Pond	OXF-58L-DL	S/B-G/S	1	66
Pasadena	PAS-T1-D	S/B	1	25
Pepperrell	PEP-16L-DB	S/B	1	66
Pulpit Rock	PUL-01-DL	HSO	1	25
Ridge Road	RRD-30L-DB	S/B	1	66
Ridge Road	RRD-67L-DB	S/B	1	66
Seal Cove	SCV-T2-D	HSO	1	15
St. John's Main	SJM-12-DB	HSO	1	15
Stamps Lane	SLA-14L-DB	S/B	1	66
Stamps Lane	SLA-14L-DL	S/B-G/S	1	66
Stamps Lane	SLA-31L-DL	S/B-G/S	1	66
Stamps Lane	SLA-11-DB	HSO	2	15
Summerville	SMV-01-DB	HSO	1	25
Salt Pond	SPO-02-DL	S/B	1	25
Summerford	SUM-01-DL	HSO	1	25
Topsail Plant	TOP-G-DB	HSO	2	15
Victoria	VIC-01-DL	HSO	1	15
Virginia Waters	VIR-05-DL	HSO	1	15

¹ The abbreviations for "Type" represent the following:

S/B Sidebreak Switch
A/B Airbreak Switch
G/S Ground Switch
HSO Hookstick Operated Switch

Table 1
Substation Switch Replacements
(continued)

Substation	Designation	Type¹	Qty Req'd	Voltage (kV)
Virginia Waters	VIR-02-DB	HSO	1	15
Virginia Waters	VIR-06-DB	HSO	1	15
Virginia Waters	VIR-07-DB	HSO	1	15
Virginia Waters	VIR-03-DL	S/B	1	15
Walbournes	WAL-352L-DL	S/B-G/S	1	66

¹ The abbreviations for “Type” represent the following:

S/B Sidebreak Switch
A/B Airbreak Switch
G/S Ground Switch
HSO Hookstick Operated Switch