

1 **Q. Re: Tab 1.1 - 2013 Facility Rehabilitation – Three Island Spillway**

2
3 **When did Newfoundland Power first become aware of the issues surrounding the**
4 **Three Island Pond Spillway?**

5
6 A. Early signs of timber deterioration were noted on an inspection from October 2005. The
7 foundation settlement and associated gate misalignment were first noted on an inspection
8 from October 2007.