

1 **Q. *Re: Tab 1.3 - New Chelsea Hydro Plant Runner Replacement and Rewind***

2
3 **What is the peak load for the generator?**

4
5 A. The rated peak load of the current turbine and generator combination is 3,700 kW. The
6 maximum load actually carried during the past year was 3,760 kW.