

1 **Q. Re: Tab 1.4 - Pitmans Pond Hydro Plant Replacement – Gate Positioner**

2
3 **Please provide any maintenance logs on the Gate Positioner.**

4
5 A. Table 1 lists all recorded maintenance activities completed on the gate positioner since
6 2005.
7
8

Table 1
Gate Positioner Maintenance

Work Order	Work Type	Date
Investigate Governor Slipping Problems	Inspection/Investigation	2007
Governor Overhaul Required	Overhaul	2007
Wicket Gate Adjustment Required	Modification	2005
Investigate Governor Operational Problems	Inspection/Investigation	2005
Oil Change	Preventative Maintenance	2005