

1 **Q. Re: Tab 2.1 - 2013 Substation Refurbishment and Modernization – Substation**
2 **Monitoring and Operations**

3
4 **Reference p. 16 of the report at Tab 2.1, where it states, “This item involves**
5 **installing meters and communications equipment at 13 Hydro infeed locations to**
6 **collect these data points on the Company’s SCADA system. These additional data**
7 **points will provide Newfoundland Power with a more accurate measurement of the**
8 **total instantaneous system load.” Are these infeed locations already monitored**
9 **through meters connected to the company’s SCADA system? If so, what standard**
10 **of accuracy is the company employing in its determination that more accuracy is**
11 **necessary?**

12
13 **A.** These locations are not currently monitored through meters connected to the company’s
14 SCADA system.