

1 **Q. [Account 362.1 and 362.2 – Wood Poles & Fixtures] – As it relates to the rebuttal**
2 **evidence set forth on pages 19 through 23 of Appendix B relating to Accounts 362.1**
3 **and 362.2 – Wood Poles & Fixtures, please provide the number and corresponding**
4 **cost of any poles retired, by year, specifically due to inspection programs since the**
5 **inception of the inspection program.**

6
7 A. Newfoundland Power's inspection program identified 88 poles for replacement in 2008
8 and 208 poles for replacement in 2009.

9
10 Newfoundland Power's accounting records do not differentiate between pole
11 replacements resulting from the inspection program and replacements for other reasons,
12 such as road widening. Therefore, the costs and precise timing of pole replacements
13 resulting from the inspection program are not available.