

1 Q. Provide the specifics of the conditions under which Hydro intends to access up to
2 60 MW of capacity assistance in 20 MW increments from Corner Brook Pulp and
3 Paper Limited.

4

5

6 A. Hydro intends to access up to 60 MW of capacity assistance in 20 MW increments
7 from Corner Brook Pulp and Paper Limited (CBPP) to reduce the risks to the
8 generation supply, in the event of lost generation capacity due to an equipment
9 forced outage or significant derating, and to maintain sufficient generation reserves
10 to meet current and anticipated customer demand. As indicated in CA-NLH-016,
11 Attachment 1, Hydro will call on CBPP to provide capacity assistance under the *Load*
12 *Reduction* steps of its Generation Reserves protocol. Hydro's Energy Control
13 Centre (ECC) staff will assess the situation prior to making the request to determine
14 how much capacity assistance is required and to provide an expected duration.
15 When capacity assistance is no longer required or the level of capacity assistance
16 can be reduced, ECC Staff will advise CBPP of the same.