

**Q. Please provide a breakdown of all your generating assets, noting age, capacity, location and present assessed capacity to perform.**

**A.** Table 1 provides a breakdown of all Newfoundland Power's hydro plants, noting location, age, rated and current capacity.

**Table 1**  
**Hydro Plant Location, Age and Capacity**

Location	Age	Rated Capacity (MW)	Current Capacity (MW)	Notes
Rose Blanche	16	6.0	6.0	
Lookout Brook G3	69	2.8	2.8	
Lookout Brook G4	69	3.0	3.0	
Sandy Brook	51	6.3	6.3	
Rattling Brook G1	56	7.4	7.4	
Rattling Brook G2	56	7.4	7.4	
Lockston G1	58	1.5	1.5	
Lockston G2	58	1.5	1.5	
Port Union G1	97	0.3	0.3	
Port Union G2	97	0.3	0.3	
Hearts Content	96	2.7	0.0	Planned Penstock Replacement
New Chelsea	58	4.3	4.3	
Pittman's Pond	55	0.6	0.6	
Victoria	110	0.6	0.6	
Seal Cove G1	90	1.3	1.3	
Seal Cove G1	90	2.3	2.3	
Topsail	82	2.6	2.6	
Petty Harbour G1	114	1.5	1.5	
Petty Harbour G2	114	1.4	1.4	
Petty Harbour G3	114	2.5	2.5	
Pierre's Brook	83	4.1	4.1	
Mobile	63	10.4	10.4	
Morris	31	1.1	1.1	
Tors Cove G1	74	2.1	2.1	
Tors Cove G2	74	2.1	2.1	
Tors Cove G3	63	2.4	2.4	
Rocky Pond	71	3.3	3.3	
Cape Broyle	61	6.3	6.3	
Horse Chops	61	8.1	8.1	
Fall Pond	75	0.4	0.4	
West Brook	72	0.7	0.7	
Lawn	84	0.6	0.6	

Table 2 provides a breakdown of all Newfoundland Power's thermal plants, noting location, age, rated and current capacity.

**Table 2**  
**Thermal Plant Location, Age and Capacity**

<b>Location</b>	<b>Age</b>	<b>Rated Capacity (MW)</b>	<b>Current Capacity (MW)</b>	<b>Notes</b>
Port aux Basques Diesel	45	2.5	2.5	
Mobile Gas Turbine	40	6.5	0.0	Planned Refurbishment
Mobile Diesel MD3	10	2.5	2.5	
Wesleyville Gas Turbine	45	10.0	0.0	Gas Generator Failure
Greenhill Gas Turbine	39	20.0	20.0	