

Q. Please provide a breakdown of the operating hours of each unit for the past 5 years and how many of these hours were due to Hydro requests.

A. Table 1 on page 3 of Schedule A to the Supplemental Application includes the run time operating hours for both the Wesleyville and Greenhill gas turbines. The table is reproduced below.

Table 1
Total Thermal Generation Run Time
(Hours)

Unit	2009	2010	2011	2012	2013	2014 YTD¹
Greenhill Gas Turbine	26.8	10.5	3.8	15.4	75.2	119.3
Wesleyville Gas Turbine	67.3	147.2 ²	68.0	35.1	70.5	32.8

Table 2 includes the run time operating hours for both the Wesleyville and Greenhill gas turbines resulting from requests from Hydro.

Table 2
Thermal Generation Run Time at Hydro's Request
(Hours)

Unit	2009	2010	2011	2012	2013	2014 YTD
Greenhill Gas Turbine	18.3	2.2	0.0	3.2	66.9	117.0
Wesleyville Gas Turbine	7.0	0.0	0.0	3.2	31.8	26.4

In 2013 and 2014 a significant percentage of run time hours for both Greenhill and Wesleyville gas turbines have been at the request of Hydro.

¹ The 2014 YTD data covers the period from January 1, 2014 to May 31, 2014. The Wesleyville Gas Turbine was not available from January 5, 2014 to January 22, 2014 and after March 5, 2014.

² During the March 2010 ice storm the Wesleyville Gas Turbine operated for 115.5 hours while repairs to transmission line 116L were undertaken. The damage to the transmission line was described on page 7 of Schedule A to the 2010 Capital Budget Supplemental Application file by the Company on April 30, 2010.