

1 **Q. Please provide any assessments completed showing the projected capital cost to**  
2 **maintain specific generating assets.**

3  
4 A. Newfoundland Power engaged experts to assess the condition of the thermal generating  
5 equipment at the Wesleyville and Greenhill facilities. These assessments completed on  
6 the gas turbine systems are included as Appendices C, D, E and F of Schedule A filed  
7 with the 2014 Supplemental Application. These assessments identified the necessary  
8 scope of work, but did not provide capital cost estimates.

9  
10 The largest capital cost item is the overhaul of the Rolls Royce AVON gas generator at  
11 Wesleyville. Section 6.1 of Schedule A explains that the cost estimate for this aspect of  
12 the work is based upon quotations provided in response to a Request for Proposals from  
13 qualified repair facilities. The capital cost estimates for the remainder of the work are  
14 based on engineering estimates completed by the Company's engineering staff for the  
15 individual items identified in the assessments referenced above.