

1 **Q. You state that the Greenhill Gas Turbine was shut down for 39.5 hrs in January**
2 **because its fuel supply was exhausted. Were you unable to operate for any of this**
3 **time because you could not source any fuel?**
4

5 A. A blizzard on January 3rd and 4th, 2014 closed the Burin Peninsula Highway making it
6 impossible for the Company's fuel supplier to deliver fuel to the Greenhill Gas Turbine
7 which is located at Grand Bank. It was during this period that the Greenhill Gas Turbine
8 was shut down. When weather and road conditions improved fuel was delivered and the
9 gas turbine went back in service immediately.