

**Q. Reference: Page 83 of 85 - Allowance for Unforeseen Items (Other) - \$750,000**

**Please provide the amount of funds used from the Allowance for Unforeseen Items for each year over the ten-year period from 2003 to 2012 setting out the number of applications for approval of an additional amount in each year.**

**A.** Table 1 provides the requested information regarding Newfoundland Power's use of the Allowance for Unforeseen Items for each year over the ten-year period from 2003 to 2012.

**Table 1**

<b>Year</b>	<b>Project Description</b>	<b>Order No.</b>	<b>Supplementary Approval</b>	<b>Actual Expenditure</b>
2012	Second cable failure of Bell Island submarine cable system	P.U. 22(2012)	\$315,000	\$315,000
2012	Tropical Storm Leslie			\$635,000
2011	Replace underground high-voltage switch, McBride's Hill, St. John's			\$305,000
2010	Ice Storm, Bonavista Peninsula, March 2010	P.U. 17(2010)	\$4,200,000	\$4,157,000
2010	Hurricane Igor, September 2010	P.U. 35(2010)	\$1,900,000	\$1,742,000
2009	Repair Kenmount Substation Power Transformer	P.U. 29(2009)	\$710,000	\$659,000
2009	Rehabilitation of Seal Cove Hydro Plant Unit 2	P.U. 38(2009)	\$375,000	\$390,000
2008	Replace Pierre's Brook Hydro Plant Transformer	P.U. 3(2008)	\$400,000	\$400,000
2007	No Use of Allowance in 2007			
2006	Cape Broyle Plant tunnel rehabilitation			\$894,000
2005	No Use of Allowance in 2005			
2004	No Use of Allowance in 2004			
2003	Lightning Storm Damage, July 2003			\$262,000
2003	Replace Bayview Substation Power Transformer Tap Changer			\$130,000