

1 Q. When was the pressure relief line last inspected and/or tested? Please provide a  
2 copy of the inspection/testing results and a copy of any report detailing follow up  
3 work carried out as a result.  
4  
5

6 A. The fuel system is visually inspected for leaks daily by the plant operator. Prior to  
7 placing the unit online, the fuel system is visually inspected by the onsite operator  
8 and maintenance staff. The unit is also periodically checked for leaks while  
9 operating. Additionally, the fuel system is inspected for condition and security of  
10 connections annually as part of the annual maintenance program. The last such  
11 inspection was completed as a part of the 2014 annual preventative maintenance  
12 program for the Hardwoods gas turbine.