

1 Q. What is the accepted utility standard in terms of frequency of inspections and testing?

2

3

4 A. As part of Hydro's Asset Maintenance Strategy review in 2011, information
5 provided by other utilities indicated that other utilities complete daily, weekly and
6 annual inspections of their fuel systems. Curtiss Wright, the Hardwoods plant
7 original equipment manufacturer, also recommended this type of regular routine
8 inspection of the gas turbine fuel supply system.