

- 1 Q. **August 2015 Hardwoods Gas Turbine Engine Refurbishment Report**
- 2 On page 6 on the report, it notes that a replacement engine has been installed in
- 3 place of engine 202224 while it is being refurbished, "...making Hardwoods
- 4 available at reduced capacity". Please state the capacity of Hardwoods since the
- 5 replacement engine has been installed.
- 6
- 7
- 8 A. The capacity of Hardwoods with the replacement engine installed is 38 MW.