

1 Q. Engine S/N 202224 was last refurbished in 2011. Table 2 on page 9 of the August  
 2 2015 report provides operating data for the Hardwoods Gas Turbine facility,  
 3 including both engines. Please provide a similar table for engine S/N 202224 only  
 4 from the time it was last refurbished in 2011.

5

6

7 A. The table below presents the operating data for the Hardwoods Gas Turbine facility,  
 8 including the information for serial number 202224 (End B) only. Please note that  
 9 the peaking and emergency hours provided for End B are included in the peaking  
 10 and emergency hours for the total plant.

11

Year	Total Operating Hours	Peaking/Emergency Hours, Total Plant	Peaking/Emergency Hours End B Only	Synchronous Condenser Hours	Available Hours
<b>2015</b> Jan to July	3,296	304	191	2,992	3,607
<b>2014</b>	6,121	355	268	5,767	6,502
<b>2013</b>	156	81	68	75	6,604
<b>2012</b>	3,893	103	89	3,790	8,259
<b>2011</b>	3,225	38	33	3,187	8,115