1	Q.	Please provide a timeline of all significant events following the March 1, 2015 fire at
2		Hardwoods including, but not limited to:
3		- Initial investigation by Hydro;
4		- Installation of replacement engine;
5		- Alba Power engagement and assessment;
6		- Borescope inspection; and
7		- Decision to refurbish.
8		
9		
10	A.	Please see the timeline from the time of the incident to the date of application to
11		the Board:
12		Incident occurred – March 1, 2015
13		Initial investigation by Hydro – March 2, 2015
14		Alba Power engaged – March 2, 2015
15		Alba Power representative onsite – March 7, 2015
16		Replacement engine components onsite – March 9, 2015
17		Borescope Inspection of combustion section and engine – March 10, 2015
18		Receipt of inspection report – March 27, 2015
19		Budgetary estimate complete – June 12, 2015
20		Approval to make application to refurbish – June 25, 2015
21		Removal of engine S/N 202224 – July 17, 2015
22		Borescope inspection of power turbine completed-July 24, 2015
23		Installation and testing of replacement engine complete – July 31, 2015
24		Power turbine inspection report received – August 26, 2015
25		Cost estimate and report finalized – August 27, 2015
26		Application submitted to the Board – September 3, 2015
27		Tender released – September 4, 2015