

1 Q. **2015 Capital Projects 500,000 and Over**

2 Replace Station Service Breakers, page C-13:

3 What is the service history for the breakers and what was addressed with each
4 service over the last five years?

5

6

7 A. In addition to regular Preventative Maintenance checks, the following corrective
8 maintenance activities were performed on these breakers:

9

- 10 • October 2012: Breaker overhaul performed on-site by a Schneider
11 Electric technician during the annual overhaul;
- 12 • December 2012: Breaker 52SST2 was sent to Schneider for a complete
13 overhaul. Insufficient components were available to perform a complete
14 overhaul; and
- 15 • January 2013: Breaker NESB3 is not working. The breaker opened
16 automatically when closed.