Page 1 of 1

1	Q.	2015 Capital Projects 500,000 and Over
2		Upgrade Generator Bearings Units 1 and 3, page C-19:
3		Please provide a status update as to the repairs or upgrades to Units 4 and 2.
4		
5		
6	A.	The generator bearing upgrade for the first of six units was approved as part of
7		Hydro's 2013 Capital Budget Application. That upgrade was completed in May 2014
8		on Unit 2. The generator bearing upgrade for the second unit was approved as part
9		of Hydro's 2014 Capital Budget Application. That upgrade is tracking with
10		compliance to schedule, with planned construction in 2015 on Unit 4.