

1 Q. **2015 Capital Projects 500,000 and Over**

2 Replace Unit 2038, page C-53:

3 What are the hours of the other three gensets in the Mary's Harbour Diesel Plant?

4

5

6 A. The total operating hours on the other three gensets in Mary's Harbour, as of
7 August 29, 2014 and rounded to the nearest 100 hours, are:

8

9 Unit 2037 103,900

10 Unit 2083 13,700

11 Unit 2090 1,000