

1 Q. **Projects over \$200,000 but less than \$500,000**

2 Upgrade Quarry Brook Dam Equipment, page D-2:

3 Hydro outlines that there are no documented major upgrades to the drain or water  
4 supply line valves near the dam. Please provide the maintenance records for the  
5 Quarry Brook Dam equipment for the past 5 years.

6

7

8 A. As stated on page D-6, there was no maintenance recorded for the Quarry Brook  
9 Dam equipment for the past five years. Maintenance is not possible due to the  
10 current condition of the equipment and the inability to establish a safe work zone  
11 for divers in the reservoir. As also stated on page D-6, once the new equipment is  
12 installed, it will be tested and maintained as per manufacturer recommendations.