

---

1    Q.    **Projects over \$200,000 but less than \$500,000**

2            Upgrade Fire Protection (Main Warehouse), page D-165:

3            Have there been any incidents with the current sprinkler system in the main  
4            warehouse prior to or after 2011 when Hydro indicates false activations occurred  
5            from power losses?

6

7

8    A.    There have been no documented false activations with the current sprinkler system  
9            in the main warehouse prior to or after 2011 which have occurred as a result of  
10           power losses.