

1 Q. **Projects over \$200,000 but less than \$500,000**

2 Increased Generation Capacity Makkovik, page D-295:

3 When were the load forecasts for Makkovik completed?

4

5

6 A. The proposal in the 2015 Capital Budget Application Increased Generation Capacity

7 Makkovik is based on a forecast completed in the Spring of 2013. Since the

8 submittal of this project, the 2014 Operating Load Forecast has been released and

9 still validates the need for more generation in Makkovik for the winter of

10 2015/2016.