

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Upgrade Transformer Differential Protection, Grandy Brook, page E-88:

3 At Appendix C, page E-95, the recommendation therein is dated August 13, 2008.

4 Has there been any update or review since that time?

5

6

7 A. There has been no review or update since August 13, 2008. The recommendation
8 stands, as the condition still exists at the Grandy Brook Terminal Station.