

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 4 Rehabilitate Salmon River Spillway, Bay d'Espoir:

3 Hydro outlines that the gates have only been used for spilling five times in the last  
4 30 years. When was the last time one of the gates was required and used for  
5 spilling?  
6  
7

8 A. The last time one of the gates at Salmon River Spillway was required and used for  
9 spilling was June 24 to 27, 2014. This is the sixth such event in the last 31 years.  
10 During this event, Gate 2 was opened a maximum of 4.0 meters and spilled an  
11 estimated total of 61.3 million cubic meters of water.