

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 4 Rehabilitate Salmon River Spillway, Bay d'Espoir:

3 Please outline the instances in the past five years where the gate rollers were
4 inoperable due to ice.

5

6

7 A. These gates were not required to be operated during winter conditions in the past
8 five years. There are no reports indicating ice build-up that would have prevented
9 operation due to successfully maintaining an ice-free condition in front of the gates
10 with the uplifters.