

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 5 Upgrade Powerhouse Roofing, Holyrood:

3 Can this project be deferred given that AMEC's 2013 assessment recommended  
4 replacement "within the next five years" (page C-12)?

5

6

7 A. The Holyrood powerhouse roof is comprised of 23 different roofing areas, which are  
8 located across the ten different levels of the powerhouse. A Level 2 condition  
9 assessment, completed by Amec in 2013, has concluded that the remaining service  
10 life for the various roof areas ranges from two to ten years.

11

12 As noted on pages 1 & 2 of the report, this project comprises the first year of a  
13 three year program for the completion of roof upgrades at the Holyrood  
14 powerhouse. This multi-year program will focus on the completion of upgrades to  
15 all roof areas, identified in the Level 2 condition assessment, as having a service life  
16 of less than five years. The roof areas to be upgraded in 2015 have been deemed to  
17 have a service life of less than two years.