

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 8 Replace ABB Exciter Unit 2- Cat Arm:

3 What was the anticipated useful life of the exciter on Unit 2 when it was put into
4 service in 1985?

5

6

7 The anticipated useful life of the Cat Arm Unit 2 exciter was 25 years when it was
8 put into service in 1985.