

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 8 Replace ABB Exciter Unit 2- Cat Arm:

3 Hydro outlines at page 7 that the complete exciter for Cat Arm has an anticipated
4 useful of life of 32 years. Is this the case for the current exciter on Unit 2?

5

6

7 A. The asset depreciation register shows 32 years for static excitation systems. This
8 register came into effect on January 1, 2011. This is not the case for the current
9 exciter on Unit 2, which was put into service in 1985 and was depreciated over 25
10 years, ending in 2010.