

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 14 Upgrade Power Transformers:

3 Has Hydro approached the manufacturer regarding this issue or contacted any
4 other utilities regarding similar experiences?

5

6

7 A. Hydro has approached the various manufacturers (ABB, Siemens and CG Global)
8 regarding gasket failures and is working with them to address the problem of failed
9 gaskets. Hydro is also aware of at least two other Canadian electrical utilities that
10 have experienced transformer gasket failures.