

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 14 Upgrade Power Transformers:

3 What is the status of the regulatory amendment and Hydro's lobbying through CEA?

4

5

6 A. The sought-after regulatory amendment has been made and comes into effect on

7 January 1, 2015. As a result, Hydro now has until 2025 to remove its PCB

8 contaminated bushings from service.