
1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 15 Wood Pole Line Management, Various Sites:

3 Why was such a small sample size used for the three nondestructive testing
4 methods?

5

6

7 A. A sample size of nine transmission poles was used for the non-destructive testing

8 evaluation. These nine poles were scheduled for removal from the field and were

9 feasibly located near access roads for transportation to Memorial University. All

10 other poles scheduled for removal were located in areas far from access roads, and

11 were therefore not feasible for transportation to the university.