

1 Q. **Projects over \$50,000 but Less Than \$200,000**

2 Tab 25 Construct Second Distribution Feeder, Nain:

3 Please outline the times over the past two years that there has been a voltage
4 unbalance in the main system.

5

6

7 A. There is always some voltage unbalance on distribution feeders with single phase
8 loads. This is because the amount of current drawn by each load is constantly
9 varying. As the voltage unbalance in Nain is not continuously monitored, the exact
10 variation in voltage unbalance cannot be provided.