

1 Q. **Project C-9: Rehabilitate Salmon River Spillway – Bay d’Espoir**

2 With reference to IC-NLH-20, have all of the “short term” recommendations
3 contained in section 6.6.1 of Hatch’s Report been completed to date? If not, which
4 recommendations have been completed and why has Hydro not completed all of
5 the recommendations to date?

6

7

8 A. With reference to the “short term” recommendations contained in section 6.6.1 of
9 Hatch’s report, a new lighting system has been installed to monitor the 3-phase
10 power supply. As well, a new distribution line to the Salmon River Spillway was
11 installed. Other short term recommendations for the Salmon River Spillway are
12 included in the scope of this proposed project to commence in 2015. Please refer
13 to the response to CA-NLH-023 for an explanation as to why Hydro has not
14 completed all of the short term recommendations to date,